

Theodore D. Schade
Air Pollution Control Officer



GREAT BASIN UNIFIED AIR POLLUTION CONTROL DISTRICT

157 Short Street, Bishop, California 93514-3537 www.gbuapcd.org

Tel: 760-872-8211 Fax: 760-872-6109 gb1@greatbasinapcd.org

January 10, 2007

Ben Doon
Ski Area Citizens' Coalition
P.O. Box 762
San Luis, CO 81152

Re: December 15, 2006 Public Records Act request, received December 20, 2006

Dear Mr. Doon:

On December 20, 2006, the Great Basin Unified Air Pollution Control District (District) received your attached request for public records regarding Notices of Violations (NOVs) and fines or other correspondence by the District issued to Mountain Utilities from January 1, 2000 to present. In accordance with the District's Public Records Act (PRA) policy, we are hereby providing copies of the following materials:

1. The PRA request,
2. The PRA extension letter from the District,
3. Index of NOVs issued to Mountain Utilities from January 1, 2000 to present,
4. Copies of NOVs and the associated settlement and release letters, including NOV numbers: 303, 307, 308, 328, 382, 384, 385, 388.

Sincerely,

Jon Becknell
Air Quality Specialist II

NOV	Source Name	Rule/Reg	Violation Description	Violation Date	NOV Date	Compliance Date	Settlement Amount
303	Mountain Utilities	210 Cond 9	Viol. 13.2 lb/hr Nox Emission Rate	01/19/01	07/02/02	01/19/01	\$300
307	Mountain Utilities	210	Exceeded NOx Emission Rate	11/25/02	11/05/03	11/26/03	\$500
308	Mountain Utilities	210.9	Exceed NOx Emission Rate	May - Sept.	09/03/04	24 hours	\$7,000
328	Mountain Utilities	210	Multiple Violations of PTO 897 Conditions 3, 9, 10, 20 during May through September 2004	10/08/04	10/08/04	10/08/04	\$29,000
382	Mountain Utilities	42402 42706	Exceeding 13.2 #/hr. Nox limit = 9 hrs and Failure to Report to Dist.	3/6, 26; 30/05	05/05/05	07/28/05	\$8,000
384	Mountain Utilities	210 Condition 20	Multiple violations of PTO 897, Condition 20 during September and October	Sept/Oct	12/01/05	Sept/Oct	\$7,000
385	Mountain Utilities	210	4 Viol. of PTO 897 Cond 9 & 1 Viol. Cond 10	Sept/Oct	01/28/06	Sept/Oct	\$5,000
388	Mountain Utilities	210	Nox emissions from the SCR exceeded the Condition 9 limit of 13.2 pounds per hour at noon on June 26, 2006 because of ammonia pump shutdown (not a breakdown)	09/20/06	09/20/06	11/12/06	\$1,000